

AC/DC CURRENT CLAMP 4100 WITH BAG

Article number: 111494

AC/DC current clamp 4100 TRMS CAT IV/1000 V - CAT III/1500 V for maximum safety. Current measurement AC/DC up to 400A, voltage measurement up to 1000 V AC and 1500 V DC, μ A measurement AC/DC for HVAC. Measurement of resistance (..40 MOhm), capacitance (10 nF..100 uF) and frequency (..10MHz). TRMS, non-contact voltage detection (NCV), LPF, diode test and continuity test. With automatic switch-off and self-test function. Flashlight, LCD display with illumination. Includes 2 test leads and 2 batteries.



Attribute	Value
Display	digital
Multiple display	No
With screen backlighting	Yes
Measuring range selection	manuell/automatisch
Temperature measurement	No
Capacitance measurement	Yes
Frequency measurement	Yes
Continuity test	Yes
True RMS value measurement (TRMS)	Yes
Interface	No
Measured value memory	Yes
Measuring circuit category	CAT IV
Max. Voltage Measuring circuit category	1000
Power measurement	No
Analog bar graph display	No
Current measuring range/DC	10 - 400
Current measuring range/AC	10 - 400
Type of current	AC/DC
Voltage measurement, AC	Yes
Voltage measurement, DC	Yes
Resistance measuring range	Yes

CIMCO Werkzeuge GmbH & Co. KG Hohenhagener Straße 1 – 5 42855 Remscheid Telefon +49 2191 3718-01 info@cimco.de • cimco.de

The technical data are empirical values according to the current state of production and are subject to customary tolerances, but do not represent guaranteed properties. We reserve the right to make technical changes.



Leakage current measurement	
Harmonic measurement	No
Measurement in cable with forward and return conductor	Yes
Pliers opening	35
Version as adapter for connection to mul- timeter	No

GTIN: 4021103107041

CIMCO Werkzeuge GmbH & Co. KG Hohenhagener Straße 1 – 5 42855 Remscheid Telefon +49 2191 3718-01 info@cimco.de • cimco.de

The technical data are empirical values according to the current state of production and are subject to customary tolerances, but do not represent guaranteed properties. We reserve the right to make technical changes.